

Marietta Water & Sewer System
SC2320004
Annual Drinking Water Quality Report
For the Year 2024

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is Greenville Water System. Greenville Water System draws its water from the Table Rock Reservoir on the South Saluda River.

A Source Water Assessment Plan has been prepared for our system. Our raw water sources are most susceptible to contamination from runoff or environmental conditions. If you have any questions about this report or concerning your water utility, please contact Charles (Billy) Humphries at Marietta Water and Sewer System. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 7:00 PM at the Marietta Water & Sewer District office located at 3213 Geer Hwy, Marietta, S.C 29661.

Marietta Water and Sewer System routinely monitors for constituents in your drinking water according to Federal and State laws. This table below shows the results of our monitoring for the period of January 1st to December 31st, 2024. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some small amounts of constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. The following chart shows our test results.

ppm: parts per million, or milligrams per liter (mg/L)

ppb: parts per billion, or micrograms per liter (µg/L)

NA: not applicable

ND: Not detected

NR: Monitoring not required but recommended.

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MNR: Monitored Not Regulated

Marietta Water and Sewer System SC# 2320004						
Contaminant	Violation Y/N	90 th percentile	Unit	Action Level	Sites over action level	Likely Source of Contamination
Copper (2021)	N	0.023 Range 0.008-0.024	ppm	1.3	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Disinfectants and Disinfection By-Products						
	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Chlorine (2024)	N	2.6 Range 1.96-3.03	ppm	4	4	Water additive used to control microbes
Haloacetic acids (HAAs) (2024)	N	13 Range 8.82-16.6661	ppb	60	N/a	By-product of drinking water disinfectant
Total trihalomethanes TTHM's (2024)	N	11 Range 6.8444-11.0921	ppb	80	n/a	By-product of drinking water chlorination

Greenville Water System (SC#2310001)						
Inorganic Contaminants	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Fluoride (2024)	N	0.63 Range 0.61-0.63	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen) (2024)	N	0.053 Range 0-0.053	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (2024) **Unregulated Contaminant	N/A	5.7 Range 5.7-5.7	ppm	N/A	N/A	Erosion of natural deposits

Turbidity				
	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.070 NTU	No	Soil runoff
Lowest monthly % meeting limit	0.3 NTU	100.000%	No	Soil runoff

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Marietta Water & Sewer District is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Marietta Water & Sewer District at (864) 836-6878. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. A lead service line inventory was completed throughout our system, in 2024. For more information on this inventory please contact us at (864) 836-6878.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

Please call our office at (864) 836-6878 if you have questions.